

Außengerät	RXTM40R2V1B		
Innengerät	FTXTM40R2V1B		
Function			
Kühlung	Ja		
Heizen	Ja		
Element	Symbol	Wert	Gerät
Design Load			
Kühlung	Pdesignc	4.00	kW
heating / Average	Pdesignh	3.80	kW
heating / Warmer	Pdesignh	-	kW
heating / Colder	Pdesignh	5.55	kW
Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj			
Tj = 35 °C	Pdc	4.00	kW
Tj = 30 °C	Pdc	2.95	kW
Tj = 25 °C	Pdc	1.90	kW
Tj = 20 °C	Pdc	1.69	kW
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	3.37	kW
Tj = 2 °C	Pdh	2.05	kW
Tj = 7 °C	Pdh	1.47	kW
Tj = 12 °C	Pdh	1.74	kW
Tj = Bivalent temperature	Pdh	3.80	kW
Tj = operating limit	Pdh	3.80	kW
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	-	kW
Tj = 7 °C	Pdh	-	kW
Tj = 12 °C	Pdh	-	kW
Tj = Bivalent temperature	Pdh	-	kW
Tj = operating limit	Pdh	-	kW
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	3.37	kW
Tj = 2 °C	Pdh	2.05	kW
Tj = 7 °C	Pdh	1.47	kW
Tj = 12 °C	Pdh	1.74	kW
Tj = Bivalent temperature	Pdh	4.53	kW
Tj = operating limit	Pdh	4.08	kW
Tj = -15 °C	Pdh	4.53	kW
Bivalent temperature			
heating / Average	Tbiv	-10	°C
heating / Warmer	Tbiv	-	°C
heating / Colder	Tbiv	-15	°C
Cycling interval capacity			
for cooling	Pcyc	-	kW
for heating	Pcyc	-	kW
Degradation co-efficient cooling**	Cdc	0.25	-
Electric power input in power models other than 'active mode'			
Off mode	Poff	0.001	kW
Standby mode	Psb	0.001	kW
Thermostat-off mode	PTO	0	kW
Crankcase heater mode	PCK	0	kW
Capacity control			
Fest	N		
Gestaffelt	N		
Variable	N		
Contact details for obtaining more information	Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium		

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.