

Außengerät	RZAG35A2V1B		
Innengerät	FTXM50R2V1B		
Function			
Kühlung	Ja	Average (mandatory)	Ja
Heizen	Ja	Warmer (if designated)	Nein
		Colder (if designated)	Nein
Element	Symbol	Wert	Gerät
Design Load			
Kühlung	Pdesignc	3.50	kW
heating / Average	Pdesignh	2.60	kW
heating / Warmer	Pdesignh	-	kW
heating / Colder	Pdesignh	-	kW
Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj			
Tj = 35 °C	Pdc	3.50	kW
Tj = 30 °C	Pdc	2.58	kW
Tj = 25 °C	Pdc	1.80	kW
Tj = 20 °C	Pdc	1.89	kW
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	2.30	kW
Tj = 2 °C	Pdh	1.40	kW
Tj = 7 °C	Pdh	1.42	kW
Tj = 12 °C	Pdh	1.66	kW
Tj = Bivalent temperature	Pdh	2.30	kW
Tj = operating limit	Pdh	3.03	kW
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	-	kW
Tj = 7 °C	Pdh	-	kW
Tj = 12 °C	Pdh	-	kW
Tj = Bivalent temperature	Pdh	-	kW
Tj = operating limit	Pdh	-	kW
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	-	kW
Tj = 2 °C	Pdh	-	kW
Tj = 7 °C	Pdh	-	kW
Tj = 12 °C	Pdh	-	kW
Tj = Bivalent temperature	Pdh	-	kW
Tj = operating limit	Pdh	-	kW
Bivalent temperature			
heating / Average	Tbiv	-7	°C
heating / Warmer	Tbiv	0	°C
heating / Colder	Tbiv	0	°C
Cycling interval capacity			
for cooling	Pcyc	-	kW
for heating	Pcych	-	kW
Degradation co-efficient cooling**	Cdc	0.25	-
Electric power input in power models other than 'active mode'			
Off mode	Poff	0.001	kW
Standby mode	Psb	0.001	kW
Thermostat-off mode	PTO	0.013	kW
Crankcase heater mode	PCK	0	kW
Capacity control			
Fest	N		
Gestaffelt	N		
Variable	N		
Contact details for obtaining more information	Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium		

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.