

Outdoor unit	RXA35A5V1B9		
Indoor unit	FTXA35B2V1BB		
<b>Function</b>			
Kühlung	Ja	Average (mandatory)	Ja
Heizen	Ja	Warmer (if designated)	Ja
		Colder (if designated)	Nein
<b>Element</b>	<b>Symbol</b>	<b>Wert</b>	<b>Maßeinheit</b>
<b>Design Load</b>			
Kühlung	Pdesignc	3.40	kW
heating / Average	Pdesignh	2.50	kW
heating / Warmer	Pdesignh	2.00	kW
heating / Colder	Pdesignh	1.33	kW
<b>Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj</b>			
Tj = 35 °C	Pdc	3.40	kW
Tj = 30 °C	Pdc	2.51	kW
Tj = 25 °C	Pdc	1.61	kW
Tj = 20 °C	Pdc	1.33	kW
<b>Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = -7 °C	Pdh	2.21	kW
Tj = 2 °C	Pdh	1.35	kW
Tj = 7 °C	Pdh	0.94	kW
Tj = 12 °C	Pdh	1.10	kW
Tj = Bivalent temperature	Pdh	2.21	kW
Tj = operating limit	Pdh	2.62	kW
<b>Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = 2 °C	Pdh	2.00	kW
Tj = 7 °C	Pdh	1.29	kW
Tj = 12 °C	Pdh	1.10	kW
Tj = Bivalent temperature	Pdh	2.00	kW
Tj = operating limit	Pdh	2.62	kW
<b>Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj</b>			
Tj = -7 °C	Pdh		kW
Tj = 2 °C	Pdh		kW
Tj = 7 °C	Pdh		kW
Tj = 12 °C	Pdh		kW
Tj = Bivalent temperature	Pdh		kW
Tj = operating limit	Pdh		kW
Tj = -15 °C	Pdh		kW
<b>Bivalent temperature</b>			
heating / Average	Tbiv	-7	°C
heating / Warmer	Tbiv	2.00	°C
heating / Colder	Tbiv		°C
<b>Cycling interval capacity</b>			
for cooling	Pcyc		kW
for heating	Pchy		kW
Degradation co-efficient cooling**	Cdc	0.25	-
<b>Electric power input in power models other than 'active mode'</b>			
Off mode	Poff	0	kW
Standby mode	Psb	0	kW
Thermostat-off mode	PTO	0	kW
Crankcase heater mode	PCK	0	kW
<b>Capacity control</b>			
Fest	N		
Gestaffelt	N		
Variable	N		
<b>Contact details for obtaining more information</b>			
Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium			
* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.			
** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.			