

Outdoor unit	RXM50B5V1B		
Indoor unit	FDXM50F3V1B9		
Function			
Kühlung	Ja		
Heizen	Ja		
	Average (mandatory) Warmer (if designated) Colder (if designated)		
	Ja Ja Nein		
Element	Symbol	Wert	Gerät
Design Load			
Kühlung	Pdesignc	5.00	kW
heating / Average	Pdesignh	4.00	kW
heating / Warmer	Pdesignh	2.16	kW
heating / Colder	Pdesignh	2.26	kW
Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur Tj			
Tj = 35 °C	Pdc	5.00	kW
Tj = 30 °C	Pdc	3.69	kW
Tj = 25 °C	Pdc	2.37	kW
Tj = 20 °C	Pdc	2.26	kW
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	3.54	kW
Tj = 2 °C	Pdh	2.16	kW
Tj = 7 °C	Pdh	1.62	kW
Tj = 12 °C	Pdh	1.92	kW
Tj = Bivalent temperature	Pdh	3.54	kW
Tj = operating limit	Pdh	3.54	kW
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	2.16	kW
Tj = 7 °C	Pdh	1.62	kW
Tj = 12 °C	Pdh	1.92	kW
Tj = Bivalent temperature	Pdh	2.16	kW
Tj = operating limit	Pdh	3.54	kW
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh		kW
Tj = 2 °C	Pdh		kW
Tj = 7 °C	Pdh		kW
Tj = 12 °C	Pdh		kW
Tj = Bivalent temperature	Pdh		kW
Tj = operating limit	Pdh		kW
Tj = -15 °C	Pdh		kW
Bivalent temperature			
heating / Average	Tbiv	-7	°C
heating / Warmer	Tbiv	2	°C
heating / Colder	Tbiv	2	°C
Cycling interval capacity			
for cooling	Pcyc		kW
for heating	Pcyc		kW
Degradation co-efficient cooling**	Cdc	0.25	-
Electric power input in power models other than 'active mode'			
Off mode	Poff	0.015	kW
Standby mode	Psb	0.015	kW
Thermostat-off mode	PTO	0	kW
Crankcase heater mode	PCK	0	kW
Capacity control			
Fest	N		
Gestaffelt	N		
Variable	N		
Contact details for obtaining more information	Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium		

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.